

Approval Number: 2001562  
Test Report: J-00342982 & J-00363685



Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

7<sup>th</sup> July 2020

Corys Plastics Industries LLC.  
Mussafah South,  
ICAD III,  
Plot 47SR37,  
PO Box 4894,  
Abu Dhabi,  
UAE

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYETHYLENE - COMPONENTS.**

**5240**

'Hepworth MDPE PE 80 Black Pipe'. Black coloured (with blue external stripes), extruded MDPE pipe. For use with water up to 60°C.

**APPROVAL NUMBER: 2001562**

**APPROVAL HOLDER: CORYS PLASTICS INDUSTRIES LLC.**

The Scheme reserves the right to review approval.  
Approval 2001562 is valid between January 2020 and January 2025

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival  
Approvals & Enquiries Manager  
Water Regulations Advisory Scheme