

Approval Number 1911529
Test Report: J-00341182 & J-00342979



28th February 2022

Corys Plastic Industries - Sole Proprietorship LLC
Mussafah South,
ICAD III,
Plot 47SR37,
PO Box 4894,
Abu Dhabi,
United Arab Emirates

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'Georg Fischer (+GF+)' (formerly known as 'Hepworth PME Green PP-R 80 Polypropylene Pipe and Hepworth PME Beige PP-R 80 Polypropylene Pipe').

Green or beige coloured, extruded polypropylene pipes. For use with water up to 85°C.

APPROVAL NUMBER: 1911529

APPROVAL HOLDER: CORYS PLASTIC INDUSTRIES - SOLE PROPRIETORSHIP LLC

The Scheme reserves the right to review approval.

Approval 1911529 is valid between November 2019 and November 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a stylized flourish at the end.

Ian Hughes
WRAS Approvals Manager